

TN012 – Sonnen – eco8 Restart Procedure

Occasionally it may be a requirement to manual restart the sonnen eco8 system.

The procedure is as follows;

Step 1: Remove top access cover via the small wing nut.

Step 2: Switch to the Off position the switch marked F1

Step 3: Wait approximately 15-20 seconds

Step 4: Hold down button S1 for 2 seconds

Step 5: Keep holding down button S1 and switch F1 into the On position

Step 6: Release button S1 after a further second.

Step 7: Replace the top access cover

The system will have now been restarted and the blue circle on the unit's main unit will re-illuminate. The system will go through its usual start-up procedure and be back online and operational with 90-120 seconds.

If you have any further questions or require support or assistance, please contact us at support@sonnen.com.au.

Yours faithfully,



James Sturch
Technical Business Manager Australia & New Zealand

